

2025

Tranquillo Pines Water Users Co-op Pump log

	PUMP 6	Well depth 460'		Pump at 440'	
	Reading	Usage	Water	Change in	GPM
	90,149,800		Level ft	water level	
January	90,327,400	177,600	429		7.25
February	90,498,400	171,000			7.25
March	90,672,100	173,700	429	0	7
April					
May					
June					
July					
August					
September					
October					
November					
December					
Totals		522,300			

	PUMP 7	Well depth 700'		Pump at 680'	
	Reading	Usage	Water	Change in	GPM
	73,487,100		Level ft	water level	
January	73,648,100	161,000	508		5
February	73,890,800	242,700			5
March	74,095,800	205,000	528		4.5
April					
May					
June					
July					
August					
September					
October					
November					
December					
Totals		608,700			

	PUMP 9	Well depth 748'		Pump at 705'	
	Reading	Usage	Water	Change in	GPM
	1,736,380		Level ft	water level	
January	1,917,840	181,460	618		4
February	2,071,330	153,490			4
March	2,234,890	163,560	710	-92	3.5
April					
May					
June					
July					
August					
September					
October					
November					
December					
Totals		498,510			

	PUMP 10	Well depth 560'		Pump at 483'	
	Reading	Usage	Water	Change in	GPM
	2,077,480		Level ft	water level	
January	2,321,340	243,860	490		5.75
February	2,551,390	230,050			5.75
March	2,808,760	257,370	499	-9	5.5
April					
May					
June					
July					
August					
September					
October					
November					
December					
Totals		731,280			

TOTAL GALLONS PUMPED		YTD		Acre/Ft
January	763,920		763,920	2.34
February	797,240		1,561,160	4.79
March	799,630		2,360,790	7.25
April	#VALUE!		#VALUE!	#VALUE!
May	#VALUE!		#VALUE!	#VALUE!
June	#VALUE!		#VALUE!	#VALUE!
July	#VALUE!		#VALUE!	#VALUE!
August	-		#VALUE!	#VALUE!
September	#VALUE!		#VALUE!	#VALUE!
October	#VALUE!		#VALUE!	#VALUE!
November	#VALUE!		#VALUE!	#VALUE!
December	-		#VALUE!	#VALUE!
Totals	#VALUE!			-