

2025 Tranquillo Pines Water Users Co-op Pump log

	PUMP 6		Well depth 460'		Pump at 440'	
	Reading	Usage	Water	Change in	GPM	
	90,149,800		Level ft	water level		
January	90,327,400	177,600	429		7.25	
February	90,498,400	171,000			7.25	
March						
April						
May						
June						
July						
August						
September						
October						
November						
December						
Totals		348,600				

	PUMP 7		Well depth 700'		Pump at 680'	
	Reading	Usage	Water	Change in	GPM	
	73,487,100		Level ft	water level		
January	73,648,100	161,000	508		5	
February	73,890,800	242,700			5	
March						
April						
May						
June						
July						
August						
September						
October						
November						
December						
Totals		403,700				

	PUMP 9		Well depth 748'		Pump at 705'	
	Reading	Usage	Water	Change in	GPM	
	1,736,380		Level ft	water level		
January	1,917,840	181,460	618		4	
February	2,071,330	153,490			4	
March						
April						
May						
June						
July						
August						
September						
October						
November						
December						
Totals		334,950				

	PUMP 10		Well depth 560'		Pump at 483'	
	Reading	Usage	Water	Change in	GPM	
	2,077,480		Level ft	water level		
January	2,321,340	243,860	490		5.75	
February	2,551,390	230,050			5.75	
March						
April						
May						
June						
July						
August						
September						
October						
November						
December						
Totals		473,910				

	TOTAL GALLONS PUMPED			YTD	Acre/Ft
January	763,920		763,920	2.34	
February	797,240		1,561,160	4.79	
March	#VALUE!		#VALUE!	#VALUE!	
April	#VALUE!		#VALUE!	#VALUE!	
May	#VALUE!		#VALUE!	#VALUE!	
June	#VALUE!		#VALUE!	#VALUE!	
July	#VALUE!		#VALUE!	#VALUE!	
August	-		#VALUE!	#VALUE!	
September	#VALUE!		#VALUE!	#VALUE!	
October	#VALUE!		#VALUE!	#VALUE!	
November	#VALUE!		#VALUE!	#VALUE!	
December	-		#VALUE!	#VALUE!	
Totals	#VALUE!			-	