

Tanquillo Pines Water Pumping Log 2021

	PUMP #7				PUMP #8				PUMP #9			PUMP#6		
	Reading	Usage	Depth		Reading	Us	Usage		Depth	Reading	Usage	Depth	Reading	Usage
<u>JAN</u>	758,087	208,900	465' 7.0 GPM		7,688	45,000	602' .9GPM		756,205	237,400	498' 5.0GPM	804,332	331,900	420' 10GPM
<u>FEB</u>	759,720	163,300	466' 5.5 GPM		8,024	33,600	607' .9 GPM		757,962	175,700	500' 4.75 GPM	807,011	267,900	421' 10 GPM
<u>MAR</u>	761,519	143,900	469' 5.0 GPM		8,370	34,600	607' 0.9GPM		759,722	176,000	493' 4.75 GPM	810,042	303,100	421' 10. GPM
<u>APR</u>	763,247	172,800	470' 5.0 GPM		8,709	33,900	610' .80 GPM		761,414	169,200	483' 4.0 GPM	812,054	201,200	415' 11 GPM
<u>MAY</u>	763,857	61,000	456' 6.0 GPM	Bad meter	9,056	34,700	595' .80 GPM		763,597	218,300	540' 9.5 GPM	813,621	156,700	405' 11GPM
<u>JUN</u>	bad meter		459' 6.0 GPM		9,382	32,600	596' .80 GPM		766,055	245,800	547' 9.0 GPM	815,054	143,300	410' 10 GPM
<u>JUL</u>	bed meter		459' 6.0 GPM		9,690	30,800	595' .80 GPM		768,564	250,900	548' 8.5 GPM	816,753	169,900	409' 11GPM
<u>AUG</u>	656,592	New Meter	458' 6.0 GPM		10,039	34,900	592' .80 GPM		771,203	263,900	555' 8.5 GPM	818,327	157,400	408' 11GPM
<u>SEP</u>	658,679	208,700	465' 6.0GPM		10,339	30,000	592' .80GPM		774,241	303,800	564' 8.0GPM	820,246	191,900	406' 11GPM
<u>OCT</u>	660,459	178,000	462' 6.0GPM		10,655	31,600	602' .80GPM		776,677	243,600	559' 8.0GPM	822,081	182,500	407, 11GPM
<u>NOV</u>	661,819	136,000	448' 6.0GPM		10,933	27,800	596' .80GPM		778,645	196,800	552' 8.0GPM	824,129	183,500	408' 10.5GPM
<u>DEC</u>	663,314	149,500	458' 6.25GPM		11,236	30,300	592' .80GPM		780,635	199,000	548' 7.5GPM	826,112	198,400	406' 10.5GPM

TOTAL GALLONS PUMPED	YTD
JAN	823,200
FEB	640,500
MAR	657,600
APR	577,100
MAY	470,700
JUN	421,700
	4,590,800

	T-G-P
JUL	451,600
AUG	456,200
SEP	733,500
OCT	635,700
NOV	544,100
DEC	577,200

YTD
4,042,400
4,498,600
5,232,100
5,867,800
6,411,900
6,989,100